

Loss Prevention Certification Board



This is to certify

EUROBOND LAMINATES LIMITED
Wentloog Corporate Park, Cardiff CF3 2ER

is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix.

Firemaster Wall Extra, Firemaster Ceiling Panel, Firemaster Wall Lite, Europanel Extra, Europanel Premier, Europanel Lite, Rockspan Extra, Rockspan Lite, Rockspan Ultima and Firemaster Wall Ultima Panels
(refer to attached appendix for details)

which have complied with the requirements of the following:

LPS 1208: Issue 2 - LPCB Fire resistance requirements for elements of construction used to provide compartmentation

Certificate No. 545a

Issue No.11

Date of Issue 9 May 2006

This certificate is valid until withdrawn by LPCB.
To check the validity and the authenticity of this certificate please visit our website www.RedBookLive.com or contact us.

Signed on behalf of the LPCB



C HILL

Page 1 of 7

LPCB is part of BRE Certification Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100
Fax +44 (0)1923 664603 www.RedBookLive.com

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions and is maintained and held in force through regular surveillance activities.

Loss Prevention Certification Board



APPENDIX TO CERTIFICATE NO. 545a

EUROBOND LAMINATES LIMITED

See end of table for notes relevant to each product

Product Name	Specification	Maximum Unsupported length (m)	Fire resistance (min) Integrity Insulation		Grade	Core Material	LPCB Ref. No
Firemaster Wall Extra	60mm thick	3.0	60	30	FR30	Mineral fibre	545a/01
	75mm thick	3.0	60	60	FR60	Mineral fibre	
	100mm thick	7.5	30	30	FR30	Mineral fibre	
	100mm thick	6.0	60	60	FR60	Mineral fibre	
	100mm thick	5.5	120	120	FR120	Mineral fibre	
	125mm thick	7.5	30	30	FR30	Mineral fibre	
	125mm thick	6.0	60	60	FR60	Mineral fibre	
	125mm thick	5.5	120	120	FR120	Mineral fibre	
	150mm thick	7.5	30	30	FR30	Mineral fibre	
	150mm thick	6.0	60	60	FR60	Mineral fibre	
	150mm thick	5.5	120	120	FR120	Mineral fibre	
	175mm thick	7.5	30	30	FR30	Mineral fibre	
	175mm thick	6.0	60	60	FR60	Mineral fibre	
	175mm thick	5.5	120	120	FR120	Mineral fibre	
	200mm thick	7.5	30	30	FR30	Mineral fibre	
	200mm thick	6.0	60	60	FR60	Mineral fibre	
200mm thick	5.5	120	120	FR120	Mineral fibre		
Firemaster ceiling panel	100mm thick	4.2	60	60	FR60	Mineral fibre	545a/02
	125mm thick	4.2	60	60	FR60	Mineral fibre	
	150mm thick	4.2	60	60	FR60	Mineral fibre	
Firemaster Wall Lite	60mm thick	3.0	60	30	FR30	Mineral fibre	545a/03
	75mm thick	3.0	60	30	FR30	Mineral fibre	

This certificate is valid until withdrawn by LPCB.
To check the validity and the authenticity of this certificate please visit our website www.RedBookLive.com or contact us.

Signed on behalf of the LPCB

C HILL

Page 2 of 7

Date of Issue 9 May 2006

Issue No. 11

LPCB is part of BRE Certification Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100
Fax +44 (0)1923 664603 www.RedBookLive.com

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions and is maintained and held in force through regular surveillance activities.

Loss Prevention Certification Board



APPENDIX TO CERTIFICATE NO. 545a

EUROBOND LAMINATES LIMITED

Product Name	Specification	Maximum Unsupported length (m)	Fire resistance (min) Integrity Insulation		Grade	Core Material	LPCB Ref. No
Firemaster	100mm thick	5.5	30	30	FR30	Mineral fibre	
Wall Lite	100mm thick	4.5	60	60	FR60	Mineral fibre	
(Continued)	100mm thick	4.0	90	60	FR60	Mineral fibre	
	125mm thick	5.5	30	30	FR30	Mineral fibre	
	125mm thick	4.5	60	60	FR60	Mineral fibre	
	125mm thick	4.0	90	60	FR60	Mineral fibre	
	150mm thick	5.5	60	60	FR60	Mineral fibre	
	150mm thick	5.0	90	90	FR90	Mineral fibre	
	150mm thick	5.0	120	90	FR90	Mineral fibre	
	175mm thick	5.5	60	60	FR60	Mineral fibre	
	175mm thick	5.0	90	90	FR90	Mineral fibre	
	175mm thick	5.0	120	90	FR90	Mineral fibre	
	200mm thick	5.5	60	60	FR60	Mineral fibre	
	200mm thick	5.0	90	90	FR90	Mineral fibre	
	200mm thick	5.0	120	90	FR90	Mineral fibre	
Europanel	86mm thick	3.0	60	60	FR60	Mineral fibre	545a/05
Extra	113mm thick	7.5	30	30	FR30	Mineral fibre	
(wall panel)	113mm thick	6.0	60	60	FR60	Mineral fibre	
	113mm thick	5.5	90	60	FR60	Mineral fibre	
	125mm thick	7.5	30	30	FR30	Mineral fibre	
	125mm thick	6.0	60	60	FR60	Mineral fibre	
	125mm thick	5.5	90	90	FR90	Mineral fibre	
	135mm thick	7.5	30	30	FR30	Mineral fibre	
	135mm thick	6.0	60	60	FR60	Mineral fibre	

This certificate is valid until withdrawn by LPCB.
To check the validity and the authenticity of this certificate please visit our website www.RedBookLive.com or contact us.

Signed on behalf of the LPCB

C HILL

Page 3 of 7

Date of Issue 9 May 2006

Issue No. 11

LPCB is part of BRE Certification Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100
Fax +44 (0)1923 664603 www.RedBookLive.com

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions and is maintained and held in force through regular surveillance activities.

Loss Prevention Certification Board



APPENDIX TO CERTIFICATE NO. 545a

EUROBOND LAMINATES LIMITED

Product Name	Specification	Maximum Unsupported length (m)	Fire resistance (min) Integrity Insulation		Grade	Core Material	LPCB Ref. No
Europanel Extra (Continued)	135mm thick	5.5	90	90	FR90	Mineral fibre	
	150mm thick	7.5	30	30	FR30	Mineral fibre	
	150mm thick	6.0	60	60	FR60	Mineral fibre	
	150mm thick	5.5	120	120	FR120	Mineral fibre	
	160mm thick	7.5	30	30	FR30	Mineral fibre	
	160mm thick	6.0	60	60	FR60	Mineral fibre	
	160mm thick	5.5	120	120	FR120	Mineral fibre	
Europanel Premier (wall panel)	86mm thick	3.0	60	30	FR30	Mineral fibre	545a/06
	113mm thick	5.5	30	30	FR30	Mineral fibre	
	113mm thick	4.5	60	60	FR60	Mineral fibre	
	113mm thick	4.0	90	60	FR60	Mineral fibre	
	125mm thick	5.5	30	30	FR30	Mineral fibre	
	125mm thick	4.5	60	60	FR60	Mineral fibre	
	125mm thick	4.0	90	60	FR60	Mineral fibre	
	135mm thick	5.5	30	30	FR30	Mineral fibre	
	135mm thick	4.5	60	60	FR60	Mineral fibre	
	135mm thick	4.0	90	60	FR60	Mineral fibre	
	150mm thick	5.5	30	30	FR30	Mineral fibre	
	150mm thick	5.5	60	60	FR60	Mineral fibre	
	150mm thick	5.0	120	90	FR90	Mineral fibre	
	160mm thick	5.5	30	30	FR30	Mineral fibre	
	160mm thick	5.5	60	60	FR60	Mineral fibre	

This certificate is valid until withdrawn by LPCB.
To check the validity and the authenticity of this certificate please visit our website www.RedBookLive.com or contact us.

Signed on behalf of the LPCB

C HILL

Page 4 of 7

Date of Issue 9 May 2006

Issue No. 11

LPCB is part of BRE Certification Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100
Fax +44 (0)1923 664603 www.RedBookLive.com

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions and is maintained and held in force through regular surveillance activities.

Loss Prevention Certification Board



APPENDIX TO CERTIFICATE NO. 545a

EUROBOND LAMINATES LIMITED

Product Name	Specification	Maximum Unsupported length (m)	Fire resistance (min) Integrity Insulation		Grade	Core Material	LPCB Ref. No
Europanel Premier (Continued)	160mm thick	5.0	120	90	FR90	Mineral fibre	
Europanel Lite (wall panel)	86mm thick	3.0	60	30	FR30	Mineral fibre	545a/07
	113mm thick	5.5	30	30	FR30	Mineral fibre	
	113mm thick	4.5	60	60	FR60	Mineral fibre	
	113mm thick	4.0	90	60	FR60	Mineral fibre	
	125mm thick	5.5	30	30	FR30	Mineral fibre	
	125mm thick	4.5	60	60	FR60	Mineral fibre	
	125mm thick	4.0	90	60	FR60	Mineral fibre	
	135mm thick	5.5	30	30	FR30	Mineral fibre	
	135mm thick	4.5	60	60	FR60	Mineral fibre	
	135mm thick	4.0	90	60	FR60	Mineral fibre	
	150mm thick	5.5	30	30	FR30	Mineral fibre	
	150mm thick	5.5	60	60	FR60	Mineral fibre	
	150mm thick	5.0	120	90	FR90	Mineral fibre	
	160mm thick	5.5	30	30	FR30	Mineral fibre	
	160mm thick	5.5	60	60	FR60	Mineral fibre	
	160mm thick	5.0	120	90	FR90	Mineral fibre	
Rockspan Extra (wall panel)	60mm thick	3.0	60	30	FR30	Mineral fibre	545a/08
	75mm thick	3.0	60	60	FR60	Mineral fibre	
	100mm thick	7.5	30	30	FR30	Mineral fibre	
	100mm thick	6.0	60	60	FR60	Mineral fibre	

This certificate is valid until withdrawn by LPCB.
To check the validity and the authenticity of this certificate please visit our website www.RedBookLive.com or contact us.

Signed on behalf of the LPCB

C HILL

Page 5 of 7

Date of Issue 9 May 2006

Issue No. 11

LPCB is part of BRE Certification Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100
Fax +44 (0)1923 664603 www.RedBookLive.com

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions and is maintained and held in force through regular surveillance activities.

Loss Prevention Certification Board



APPENDIX TO CERTIFICATE NO. 545a

EUROBOND LAMINATES LIMITED

Product Name	Specification	Maximum Unsupported length (m)	Fire resistance (min) Integrity Insulation		Grade	Core Material	LPCB Ref. No
Rockspan	100mm thick	5.5	120	120	FR120	Mineral fibre	
Extra	125mm thick	7.5	30	30	FR30	Mineral fibre	
(Continued)	125mm thick	6.0	60	60	FR60	Mineral fibre	
	125mm thick	5.5	120	120	FR120	Mineral fibre	
	150mm thick	7.5	30	30	FR30	Mineral fibre	
	150mm thick	6.0	60	60	FR60	Mineral fibre	
	150mm thick	5.5	120	120	FR120	Mineral fibre	
	175mm thick	7.5	30	30	FR30	Mineral fibre	
	175mm thick	6.0	60	60	FR60	Mineral fibre	
	175mm thick	5.5	120	120	FR120	Mineral fibre	
Rockspan Lite	60mm thick	3.0	60	30	FR30	Mineral fibre	545a/09
(wall panel)	75mm thick	3.0	60	30	FR30	Mineral fibre	
	100mm thick	5.5	30	30	FR30	Mineral fibre	
	100mm thick	4.5	60	60	FR60	Mineral fibre	
	100mm thick	4.0	90	60	FR60	Mineral fibre	
	125mm thick	5.5	30	30	FR30	Mineral fibre	
	125mm thick	4.5	60	60	FR60	Mineral fibre	
	125mm thick	4.0	90	60	FR60	Mineral fibre	
	150mm thick	5.5	30	30	FR30	Mineral fibre	
	150mm thick	5.5	60	60	FR60	Mineral fibre	
	150mm thick	5.0	120	90	FR90	Mineral fibre	
	175mm thick	5.5	30	30	FR30	Mineral fibre	

This certificate is valid until withdrawn by LPCB.
To check the validity and the authenticity of this certificate please visit our website www.RedBookLive.com or contact us.

Signed on behalf of the LPCB

C HILL

Page 6 of 7

Date of Issue 9 May 2006

Issue No. 11

LPCB is part of BRE Certification Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100
Fax +44 (0)1923 664603 www.RedBookLive.com

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions and is maintained and held in force through regular surveillance activities.

Loss Prevention Certification Board



APPENDIX TO CERTIFICATE NO. 545a

EUROBOND LAMINATES LIMITED

Product Name	Specification	Maximum Unsupported length (m)	Fire resistance (min) Integrity Insulation		Grade	Core Material	LPCB Ref. No
Rockspan Lite	175mm thick	5.5	60	60	FR60	Mineral fibre	
(Continued)	175mm thick	5.0	120	90	FR90	Mineral fibre	
Rockspan Ultima (wall panel)	150mm thick	7.5	240	240	FR240	Mineral fibre	545a/10
	175mm thick	7.5	240	240	FR240	Mineral fibre	
Firemaster Wall Ultima	150mm thick	7.5	240	240	FR240	Mineral fibre	545a/11
	175mm thick	7.5	240	240	FR240	Mineral fibre	
	200mm thick	7.5	240	240	FR240	Mineral fibre	

Notes:

- 1) **LPCB ref 545a/01, 545a/02, 545a/03, 545a/05, 545a/06, 545a/07, 545a/08, 545a/10 and 545a/11** - Wall panels can be installed vertically or horizontally.
- 2) **LPCB ref 545a/01 and 545a/08** - Where Eurobond 120 rock fibre insulation core is used in the 100mm thick panels, the fire resistance insulation performance is reduced to 90 minutes.
- 3) **LPCB ref 545a/10 and 545a/11** - Rockspan Ultima and Firemaster Wall Ultima wall panel joints to be stitched on both internal and external faces using 4.7mm diameter x 20mm long self-tapping screws at 300mm centres.

This certificate is valid until withdrawn by LPCB.
To check the validity and the authenticity of this certificate please visit our website www.RedBookLive.com or contact us.

Signed on behalf of the LPCB

C HILL

Page 7 of 7

Date of Issue 9 May 2006

Issue No. 11

LPCB is part of BRE Certification Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100
Fax +44 (0)1923 664603 www.RedBookLive.com

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions and is maintained and held in force through regular surveillance activities.